

Wheatland's



Schedule 10



Sprinkler Pipe

Wheatland's Schedule 10 Sprinkler Pipe is a high quality sprinkler pipe offering you the full range of assurances you require. Schedule 10 Sprinkler Pipe has passed some of the toughest lab tests ever created for sprinkler pipe.

Made in the U.S.A. by Wheatland Tube Company means made to the highest standards for consistent quality.

Specifications and Approvals

Wheatland's schedule 10 Sprinkler Pipe is made from the highest quality steel in one of the nation's most modern and most complete pipe manufacturing plants. Our proprietary mill coating offers you a clean, corrosion and heat resistant surface that outlasts and outperforms standard lacquer coatings. Plus, this coating can be quickly and easily painted without special preparation. Or it may be hot-dipped galvanized to meet FM requirements for dry systems in accordance with the zinc coating specification of ASTM A795 or A53.

Wheatland's Schedule 10 Lightwall Sprinkler Pipe meets or exceeds the following:

- UL & C-UL Listed
- FM Approved
- ASTM A135, Grade A

Please refer to appropriate documentation for up-to-date listing and approval information. Specifications and descriptions are accurate as known at time of publication and are subject to change without notice.

Specifications										
NPS	Nominal O.D		Nominal I.D		Nominal Wall		Nominal Weight		UL CRR*	Pieces Lift
	in.	mm	in.	mm	in.	mm	lbs./ft.	kg/m		
1 1/4	1.660	42.2	1.442	36.6	.109	2.77	1.81	2.69	7.3	61
1 1/2	1.900	48.3	1.682	42.7	.109	2.77	2.09	3.11	5.8	61
2	2.375	60.3	2.157	54.8	.109	2.77	2.64	3.93	4.7	37
2 1/2	2.875	73.0	2.635	66.9	.120	3.05	3.53	5.26	3.5	30
3	3.500	88.9	3.260	82.8	.120	3.05	4.34	6.46	2.6	19
4	4.500	114.3	4.260	108.2	.120	3.05	5.62	8.37	1.6	19
5	5.563	141.3	5.295	134.5	.134	3.40	7.78	11.58	1.5	13
6	6.625	168.3	6.357	161.5	.134	3.40	9.30	13.85	1.0	10

* Calculated using Standard UL CRR formula, UL Fire Protection Directory, Category VIZY

* The CRR is a ratio value used to measure the ability of a pipe to withstand corrosion. Threaded Schedule 40 steel pipe is used as the benchmark (value of 1.0).



Effective February 23, 2009



Wheatland Tube Company

700 South Dock Street, Sharon, PA 16146

Ph 800.257.8182 Fax 724.346.7260

www.wheatland.com



Coated Black Sprinkler Pipe