


Product			
Striker Plates			
Project Information			
Job Name:		Date Submitted:	
Location:		Submitted By:	
Engineer:		Approved By:	
Contractor:		Manufacturer's Rep:	
Installation			
Must be installed in accordance with the TracPipe Design Guide and Installation Instructions and all applicable codes			
Application Information			
Protection from Potential Puncture			
Technical Data			
<u>Materials</u>			
Hardened Steel RB >75			
<u>Pressure Ratings (used with tubing)</u>			
N/A			
<u>Temperature Ratings (used with tubing)</u>			
Operating Temperature Range		N/A	
Codes			
ICC Codes (IFGC, IRC, IMC, IPC), NFPA 54, UPC, CAN/CSA B149.1, NFPA 58, UPC			
Standards			
ANSI LC1 / CSA 6.26, ANSI Z223.1			
Listings			
CSA, ICC PMG 1046 / 1052/ 1058 IAPMO (UPC) File No.3682 / 4665 / ES ER-0227			
Dimensional Information			
✓			
	<i>P/N</i>	<i>L x W</i>	<i>Weight (lbs)</i>
<input type="checkbox"/>	FGP-SP-025	1-1/2" x 3"	0.1
<input type="checkbox"/>	FGP-SP-050	6-1/2" x 3"	0.3
<input type="checkbox"/>	FGP-SP-075	8" x 3"	0.4
<input type="checkbox"/>	FGP-SP-100	11-1/2" x 3"	0.6
<input type="checkbox"/>	FGP-SP-617	17" x 6-1/2"	1.8

Omega Flex, Inc. * 451 Creamery Way* Exton, PA 19341

Tel: 610-524-7272 * Toll Free: 800-671-8622 * Fax: 610-524-7282

www.omegaflex.com