

**Product**

**Striker Plates**

**Project Information**

|             |                     |
|-------------|---------------------|
| Job Name:   | Date Submitted:     |
| Location:   | Submitted By:       |
| Engineer:   | Approved By:        |
| Contractor: | Manufacturer's Rep: |

**Installation**

Must be installed in accordance with the TracPipe Design Guide and Installation Instructions and all applicable codes

**Application Information**

Protection from Potential Puncture

**Technical Data**

Materials

Hardened Steel RB >75

Pressure Ratings (used with tubing)

N/A

Temperature Ratings (used with tubing)

Operating Temperature Range N/A



**Codes**

ICC Codes (IFGC, IRC, IMC, IPC), NFPA 54, UPC, CAN/CSA B149.1, NFPA 58, UPC

**Standards**

ANSI LC1 / CSA 6.26, ANSI Z223.1

**Listings**

CSA, ICC PMG 1046 / 1052/ 1058 IAPMO (UPC) File No.3682 / 4665 / ES ER-0227

**Dimensional Information**

|                                     | P/N        | L x W        | Weight (lbs) |
|-------------------------------------|------------|--------------|--------------|
| <input checked="" type="checkbox"/> |            |              |              |
| <input type="checkbox"/>            | FGP-SP-025 | 1-1/2" x 3"  | 0.1          |
| <input type="checkbox"/>            | FGP-SP-050 | 6-1/2" x 3"  | 0.3          |
| <input type="checkbox"/>            | FGP-SP-075 | 8" x 3"      | 0.4          |
| <input type="checkbox"/>            | FGP-SP-100 | 11-1/2" x 3" | 0.6          |
| <input type="checkbox"/>            | FGP-SP-617 | 17" x 6-1/2" | 1.8          |

Omega Flex, Inc. \* 451 Creamery Way\* Exton, PA 19341

Tel: 610-524-7272 \* Toll Free: 800-671-8622 \* Fax: 610-524-7282

www.omegaflex.com